

Data sheet for LT XLPE Cable

S.No	Particulars	3.5 X 120
1	Name of Manufacturer	Polycab Wires Pvt. Ltd, Daman
2	Item Code	SISLV3.5X12010618
3	Type of cable	2XFY
4	Voltage Grade V	1100
5	No of cores X size in sqmm	3.5 X 120
6	Conductor	
a)	Material	Plain annealed Copper as per Class 2 of IS:8130/84
b)	Max. d.c. resistance of conductor at 20° C (ohm/km)	
	Main	0.153
	Neutral	0.268
c)	Shape of the conductor	Stranded Compacted Sector
7	Insulation	
a)	Material	XLPE as per IS 7098(Pt-1)/88, Latest
b)	Nominal thickness (mm)	
	Main	1.2
	Neutral	1.1
8	Inner Sheath	
a)	Material	Extruded PVC Type ST2 as per IS:5831/84
b)	Minimum thickness (mm)	0.4
9	Armouring	
a)	Material	Galvanised Steel
b)	Type of armouring	Flat Strip
c)	Nominal size of armour (mm)	4.0 x 0.8
10	Outer Sheath	
a)	Material	FRLS PVC Type 'ST2' as per IS:5831/84
b)	Thickness (mm)	1.72 (Min.)
11	Electrical Parameters	
a)	Max. a.c. resistance of conductor at 90° C (ohm/km)	0.196
b)	Calculated Cable reactance (ohm/km)	0.0713
c)	Impedance of cable (ohm/km)	0.209
d)	Approx. Cable Capacitance (mfd/km)	0.67
12	Maximum conductor temperature under normal operating conditions	90°C
13	Maximum conductor temperature at the termination of short circuit	250°C
14	Short Circuit rating of conductor for the duration of 1 sec (kA)	17.17



POLYCAB WIRES PVT. LTD.

Polycab House, 771, Mogul Lane, Mahim (W), Mumbai 400 016, India.
Tel.: +91 22 2432 7070-74 | Fax: +91 22 2432 7075 | Email: bdg@polycab.com | www.polycab.com



15	Continuous Current carrying capacities :-	
(a)	In Ground at 30°C (A)	287
(b)	In Air at 40°C (A)	320
16	Applicable Standard	IS 8130/84, IS 7098 Part I/88, IS 5831/84, IS 3975/88 etc. with latest up to date amendments
17	Approx. overall diameter of the cable in mm	39.0 ± 2.0
18	Minimum bending radius	12 times Overall diameter
19	Max. Tensile strength	
(i)	for Cables pulled with stocking (Newtons)	9 x D ² , D is the cable OD in mm
(ii)	for Cables pulled with pulling eyes (N)	21,500
20	Colour of outer sheath.	Black

Note:-The values given above are subject to tolerances as per the relevant standards.



India's No.1 Cable & Wires Company



Works - Daman:
52/5-8, Daman Industrial Estate,
Village Kadaiya, Daman - 396210.
Tel : (0260) 3091031/070, 2220422 /425/428
Fax : (0260) 2221009

Works - Halol:
Unit 4, Plot No. 67-72, Nurpura,
Taluka - Halol, District Panchmahal,
Gujarat 389350.
Tel: 02676 320862/326801